



Use of Space Heaters

Space heaters should be used as a last resort, and only after NCCU personnel have tried to correct heating requirements by the central heating system. The first step toward mitigating a heating requirement is to submit a School Dude request.

All space heaters used on the NCCU campus must meet the following requirements:

- Must have fully enclosed heating surfaces
- Must have a thermostat and a tip-over safety shutoff
- Must be listed by an approved listing agency such as Underwriter Laboratories
- Must plug directly into a regular 120-volt AC receptacle
- Must not require an extension cord or any temporary wiring
- Used in a location that is free of combustibles
- Does not create a trip hazard
- Portable liquid, gas or solid-fuel heaters are not allowed on campus



Listing of Approved Testing Laboratories

The presence of the below marks indicates a space heater has been tested by a laboratory that has been approved by the NC Department of Insurance

